

## CHAPTER 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

**[F] 918.1 General.**

In-building two-way emergency responder communication coverage shall be provided in all new buildings in accordance with [Section 510](#) of the *International Fire Code*.